



Nashik Municipal Corporation  
Fire & Emergency Services Nashik  
Hutatma Veer Bapurao Gaidhani Fire Station Shingada Talav Nashik 422001



Visti us at : www.nashikcorporation.com

E-mail : cfo@nmc.gov.in

PBX No : 2575631, 2575632, 2575633, 2575634, 2577921, 2577923,  
2571479, 2577952, 2315967, 2581252 Fax : (0253) 2577936, 2315704

**FIRE & EMERGENCY SERVICE**  
**NMC / FIRE / WS / 307 / 2024**  
**DATE - 28 / 06 / 2024**

## Appendix XII

### FIRE SAFETY CERTIFICATE

Certified that the existing building **Cambridge School** at S.No.31/1/2 (P), Mhasrul Shiwar, Dindori Road, Nashik. comprised of **Ground & 02 (Two Blocks) (upper floors)** owned **St. Xavier's Education Trust (Aurangabad)** have complied with fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the officers concerned of Fire Service on 28/06/2024 in the presence **Collins Albugnerque Chairman** and that the building/premises is fit for occupancy upto classes Grade X with effect from 28/06/2024 for a period of **One years** in accordance with rule and subject to compliance of the specific conditions as appended.

Issued on 28/06/2024 at Nashik by




Signature with Seal : \_\_\_\_\_

Name : \_\_\_\_\_

Designation : \_\_\_\_\_

Name & Address of  
Department / Office : \_\_\_\_\_

  
28/6/2024

Sanjay K. Bairagi

Chief Fire Officer

**Rajiv Gandhi Bhavan,**  
**Sharanpur Road, P.B.No.**  
**12, Nashik - 422001**

To,  
**Cambridge School**  
**S. No.31/1/2 (P), Mhasrul Shiwar,**  
**Dindori Road, Nashik.**



# NASHIK MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

E mail :- cfo@nashikcorporation.in

Office of the Chief Fire Officer

Ref. No: NMC / FIRE / WS / Edu.- 12 / 2023;

DATE: 16 / 03 / 2023

To,

M/s. ST. Xavier's Education Trust (Aurangabad)

C/o Shri, R. V. Nadkarni (Nadkarni Mahajan & Associate), Architect, Nashik

**Sub:** Final NOC under Maharashtra Fire Prevention & Life safety Measures Act, 2006, for Construction of Educational Building In S. No. 31/1/2 (P), Mhasrul Shiwar, Nashik.

- Ref :-
1. This office Provisional letter no.NMC/FIRE/WS/II/Edu.-03/2021; Dated 23/06/2021
  2. NMC Commencement Certificate No.LND/BP/C2/160/2021, Date: 30/06/2021,
  3. Fire Prevention Fund Rs. 3,37,500/- ( Fire Fund Rs. 3,12,500/- + Inspection Fee Rs. 25,000/-) Paid wide Book No. 09544, Pass No. 033, dated 21/06/2021
  4. Inspection of system installed in building on date 15/03/2023

With ref. to above-mentioned subject, the representative of this department visited the said premises for Educational Building In S. No. 31/1/2 (P), Mhasrul Shiwar, Nashik. in presence M/s. ST. Xavier's Education Trust (Aurangabad) for inspection of Fire prevention & protection arrangements provided by you. The Fire protection system, (wiz Hose reel system / Down Comer /Yard Hydrant / Terrace Tank / Fire Pump) installed are found in satisfactory working Condition.

- 1) The fire protection systems installed in the building should be maintained in high efficiency state and in the proper working condition at all time during the use of the building by owner or occupier.
- 2) Staircases and Escape routes should be kept free of obstructions.
- 3) Side marginal open space from all-sides of building should be kept open, free of obstructions & motor able. It shall be hard enough to take load of 40 ton Fire Appliance.
- 4) Fire protection system provided in the building should not be tempered / altered or removed from the building for any reason without permission of this department.
- 5) It will be the sole responsibility of the OWNER / OCCUPIER to submit every six months i.e. in January and July, a certificate in the prescribed form issued by a Licensed agency, approved by Chief Fire Officer, NMC regarding the compliance of the Fire Prevention and Life Safety Measures in the building under clause 3(3) of Maharashtra Fire Prevention and Life Safety Measures Act 2006.
- 6) On contravention of any of above conditions, action will be taken against the owner/occupier and / or builder under Maharashtra Fire Prevention and Life Safety Measures Act 2006, clause 3, 4, 8 & 36 and this N.O.C. will stand cancelled without any notice and the owner / occupier and / or the builder will be solely responsible to loss of life or property, if any.
- 7) The undersigned reserves rights to amend any additional recommendations deemed fit during the inspections due to statutory provisions amended from time to time and interest of the protection of life and property.
- 8) This certificate is issued on the basis of approved drawings and commencement certificate issued by Town Planning Department NMC under ref.no.2 & the equipments shown on site and information submitted in written by the owner and/or builder of the building. The owner and / or builder of the building & Licensee agency which carried out the Fire protection work of the building will be solely responsible for any false information.

- NOTE:-
- 1) The Licensed Agency which has installed the Fire Protection system will be responsible for servicing & maintenance of the system for next five years and to issue the 'Form B' certificate as per clause (6) above.
  - 2) This NOC is given only for Active Fire Protection System i.e. for actual fire protection installations such as Down comer etc. and not for Passive Fire Protection e.g. Alternate staircase, Fire lift, Generator etc.
  - 3) Fire brigade officials will not be responsible for any accident due to lack of Passive Fire Protection System. The Architect / Engineer, owner and / or builder and Licensed agency which carried out the Fire protection work of the building will be fully responsible for the same.

Copy to:  
ADTP / Executive Engineer,  
Town Planning Deptt., NMC



Chief Fire Officer,  
Nashik Municipal Corporation

